



Pre-Feasibility Report

PV + BESS Project

Prepared by: Super Admin

Report date: 12 June 2026

Coordinates: 45.6113N, 5.6322E

Altitude: 210 m a.s.l.

DC Capacity: 19.825 MWp

Annual Yield P50: 26,447 MWh/yr

Annual Yield P90: 24,322 MWh/yr

LCOE: 3.94 cEUR/kWh

IRR: 52.8%

Site Area: 27.47 ha (274,684 m²)

Layout Panels: 26,791 modules x 19.825 MWp

Simulation Weather Source: PVGIS

STRICTLY CONFIDENTIAL -- This report is prepared for the sole use of the named client. Results are based on computer-modelled estimates using PVGIS 5.2 TMY data. They should not be relied upon for final investment decisions without an independent energy assessment.



SADE **PVInvest**

www.sade.systems

Table of Contents

1. Executive Summary [PV]

2. System Configuration [PV]

3. Meteorological Data [PV]

4. Loss Analysis [PV]

5. Yield Uncertainty & Exceedance Probability [PV]

6. Financial Analysis [PV]

7. Bill of Quantities [PV]

8. Battery Storage (BESS) Investment Analysis [BESS]

9. PV + Storage Dispatch & Combined Economics [PV+BESS]

10. Methodology & Standards Reference

11. Disclaimer

3

4

6

8

9

10

11

13

16

18

19

1. Executive Summary [PV]

DC Installed Capacity	19.825 MWp
Number of Modules	26,791
Annual Energy (P50)	26,447 MWh/yr
Annual Energy (P90)	24,322 MWh/yr <- lender reference
Specific Yield	1,338 kWh/kWp/yr
Performance Ratio	84.7%
Combined Uncertainty 1-sigma	6.2%
CAPEX	EUR 8.92M (EUR 0.450/Wp)
NPV (25yr)	EUR 51.88M
IRR	52.8%
LCOE	3.94 cEUR/kWh
Simple Payback	1.9 years
CO2 Avoided (annual)	11,940 t CO2/yr

P90 represents the annual yield exceeded in 9 out of 10 years based on combined meteorological and model uncertainty (IEC 61724-1:2021 Annex C). It is the standard reference for project debt sizing.

2. System Configuration [PV]

Site Layout

Site Area	27.4700 ha (274,684 m²)
Layout Panel Count	26,791 modules
DC Capacity (layout)	19.825 MWp
Total Vertices	4
BESS Layout Capacity	59.48 MWh (59,475 kWh)




Figure — Parcel boundary schematic (north up). Blue = panel rows, cyan = BESS, amber = transformers, green = building. Corner labels in WGS84 decimal degrees.

Parcel Corner Coordinates (WGS84)

#	Latitude (°N)	Longitude (°E)
1	45.608984	5.628867
2	45.608984	5.635598
3	45.613692	5.635598
4	45.613692	5.628867

Module

Manufacturer / Model	Jinko Solar JKM740N-82HL4-MPS Tiger Neo 740W
Cell Technology	N-type TOPCon
Rated Power (STC)	740 Wp
Open-Circuit Voltage Voc	49.30 V
Short-Circuit Current Isc	20.18 A
Temp. Coeff. Pmax	-0.300 %/degC
Bifaciality Factor	0.80
Module Area	3.216 m2
Module Efficiency (STC)	23.00%

Inverter & DC Stringing

Manufacturer / Model	Huawei SUN2000-125KTL-M0
AC Rated Power	125 kW
MPPT Voltage Range	200 - 1500 V
Max. DC Voltage	1500 V
Number of Inverters	145
Modules per String	27
Strings per Inverter	7
Total DC Strings	1,015
String Voc (STC-10 degC cold)	1454 V
String Vmp (nominal 25 degC)	1107 V
DC/AC Ratio	1.120

3. Meteorological Data [PV]

Irradiation and weather data from PVGIS 5.2 (JRC, European Commission). Typical Meteorological Year (TMY) compiled per ISO 15927-4:2005 -- Finkelstein-Schafer statistics, 12 representative months selected from >=15 years of satellite radiation data. Hourly resolution (8 760 records/yr) used for all energy calculations.

Month	AC Energy (kWh/yr)
Jan	1,248,083
Feb	1,601,250
Mar	2,362,958
Apr	2,168,903
May	3,426,887
Jun	2,775,615
Jul	3,105,244
Aug	3,181,308
Sep	2,513,688
Oct	2,187,424
Nov	1,191,677
Dec	771,365
Annual Total	26,534,404




Figure 1 -- Monthly AC energy production (MWh). Values above bars in MWh.

Weather Source Cross-Validation

Annual GHI independently verified against PVGIS 5.2 (JRC European Commission) and NASA POWER (NASA Langley Research Center) per IEC 61724-1:2021 S5.2 cross-validation requirement. Differences <=5% are considered acceptable.

PVGIS 5.2 (JRC) Annual GHI	1,501 kWh/m2/yr <- used for simulation
NASA POWER Annual GHI	1,367 kWh/m2/yr
Difference (NASA - PVGIS)	-8.9% -- Exceeds +/-5% -- additional source recommended
Simulation Source	PVGIS



Figure -- Annual GHI comparison: PVGIS 5.2 (blue) vs NASA POWER (green). Arrow (<-) indicates source used for energy simulation.

WARNING: GHI difference -8.9% between PVGIS 5.2 and NASA POWER exceeds the IEC 61724-1:2021 +/-5% independent-source acceptance criterion. Site-specific measurement data or a third independent dataset is recommended before final investment decision.

4. Loss Analysis [PV]

Loss chain follows IEC 61724-1:2021. Each factor is applied sequentially from plane-of-array irradiance to net AC energy at the point of connection.

Loss Component	Value (%)	Standard Reference
Cell temperature derating	-0.93	IEC 61215-2:2021 S8
IAM optical (angle-of-incidence)	-6.14	IEC 61853-2:2016
Soiling / contamination	-2.00	IEC 61724-1:2021
LID (light-induced degradation)	-1.50	IEC 61724-1:2021
Module mismatch	-1.00	IEC 61724-1:2021
DC wiring ohmic	-1.50	IEC 61724-1:2021
Inverter conversion	-1.20	IEC 61683:2021
AC wiring	-0.50	IEC 60364-7-712:2017
MV transformer	-1.00	IEC 60076-1:2011
System availability	-1.00	IEC 61724-1:2021

Net Performance Ratio: 84.7% (IEC 61724-1: AC energy / (GHI x module area x STC efficiency))




Figure 2 -- Loss cascade components. Green = gain.

5. Yield Uncertainty & Exceedance Probability [PV]

Uncertainty evaluated per IEC 61724-1:2021 Annex C -- RSS combination of independent uncertainty sources. Monte Carlo with 2 000 samples from a lognormal distribution.

Uncertainty Budget

Uncertainty Source	1-sigma Value (%)
Ghi Interannual	4.0
Ghi Model	3.0
Transposition	2.0
Module Power	2.0
Temperature Model	1.5
Soiling	1.0
Mismatch Wiring	1.0
Inverter	0.5
Availability	1.0
Combined RSS -- 1-sigma	6.2

Annual Yield Exceedance Probabilities

Level	MWh/yr	Definition	Primary Use Case
P50	26,447	50% of years exceed this	Energy contracts
P70	25,585	70% of years exceed this	Conservative planning
P90	24,322	90% of years exceed this	Debt sizing reference
P99	22,830	99% of years exceed this	Worst-case / insurance



Figure 3 -- Annual yield at exceedance probabilities. P90 (amber) is the lender reference.

P90 = 10th percentile of simulated distribution. In lender convention, P90 = energy exceeded in 90% of years.

6. Financial Analysis [PV]

CAPEX	EUR 8.92M (EUR 0.450/Wp)
OPEX (annual)	EUR 198,253/yr
Electricity Tariff	18.00 cEUR/kWh
Discount Rate (WACC)	7.0%
Project Lifetime	25 years
NPV (25yr)	EUR 51.88M
IRR	52.8%
LCOE	3.94 cEUR/kWh (IEC TR 62936:2020)
Simple Payback	1.9 years
CO2 Avoided (annual)	11,940 t CO2/yr
CO2 Avoided (25yr)	298,512 t CO2

Cumulative Cash Flow Milestones

Year	Cumulative CF (EUR M)	Cumulative CF / CAPEX
1	EUR -4.34M	-48.7%
5	EUR 14.65M	164.2%
10	EUR 40.00M	448.4%
15	EUR 67.27M	754.1%
20	EUR 96.60M	1082.8%
25	EUR 128.13M	1436.3%




Figure 4 -- Cumulative cashflow over 25-year project lifetime (MEUR). Blue dashed line = simple payback year.

LCOE per IEC TR 62936:2020. CO2 grid factor: 0.5 kg CO2/kWh (IEC TS 62257-9-8 basis).

7. Bill of Quantities [PV]

Indicative Bill of Quantities derived from simulation inputs per IEC 62548:2016. Quantities follow standard industry sizing rules (string combiners at 12 strings, cable runs estimated from GCR and panel count). Actual prices depend on project scale, region, and market conditions.

PV Modules

Item	Specification	Qty	Unit
Jinko Solar JKM740N-82HL4-MPS Tiger Neo 740W	740Wp N-type TOPCon — 3.22m ² — η23.0%	26,791	pc

Inverters

Item	Specification	Qty	Unit
Huawei SUN2000-125KTL-M0	125kW AC, 200–1500V MPPT	145	pc

Mounting Structures

Item	Specification	Qty	Unit
Ground-mount fixed-tilt frame (hot-dip galvanised)	Dual-portrait, 2 modules/frame, wind class II per EN 1991-1-4	13,396	frame
Driven steel pile Ø76mm × 1.5m	Hot-dip galvanised S355, 4 piles/frame	53,584	pc

DC Wiring & Protection

Item	Specification	Qty	Unit
DC string cable 6mm ² (H1Z2Z2-K)	1.5kV DC rated, halogen-free, UV resistant	56,840	m
DC main cable 16mm ² (H1Z2Z2-K)	1.5kV DC, SCB to inverter DC inputs	4,250	m
DC string combiner box (12-input, IP65)	12-input, fused, monitoring connector, stainless hardware	85	pc
DC string fuse 10A gPV (10×38mm)	1000V DC, 10A, aR/gPV	1,015	pc
DC surge protector Type II (1000V DC)	I _{max} 40kA 8/20us, pluggable varistor module	85	pc
DC load-break isolator 1000V / 32A	2-pole, 1000V DC, 32A, lockable	1,160	pc

AC Wiring & Protection

Item	Specification	Qty	Unit
AC output cable 35mm ² (YKY / FG16OR16)	0.6/1kV, XLPE insulated, 4-conductor	21,750	m
AC main circuit breaker	4-pole, rated to inverter output, I _{cu} ≥10kA	145	pc
AC surge protector Type II (275V AC)	I _{max} 40kA, 3P+N, pluggable module	145	pc

Medium Voltage

Item	Specification	Qty	Unit
Dry-type MV transformer 953kVA	953kVA, 0.4/10(20)kV, AN cooling, IP23 enclosure	19	pc
MV ring main unit (RMU) 24kV	SF6 insulated, 2x cable + 1x transformer bay	19	pc

Monitoring & Control

Item	Specification	Qty	Unit
Plant data logger / SCADA gateway	RS-485 Modbus + Ethernet + 4G, cloud telemetry	1	lot
On-site weather station	Class-A pyranometer, ambient + module temp, anemometer	1	set

Revenue-grade smart meter (MID Class 0.5S)	Class 0.5S active energy, MID 2014/32/EU certified	1	pc
--	--	---	----

Civil & Site Works

Item	Specification	Qty	Unit
Security perimeter fence (2m height)	Galvanised chain-link, concrete posts, anti-climb top rail	2,134	m
Internal gravel access road (4m width)	200mm compacted gravel, geotextile base, drainage gradient	232	m
Cable trenching (300x700mm)	300mm wide, 700mm deep, sand bedding, warning tape, reinstatement	21,402	m
Earthing / grounding system	Copper mesh 50mm², driven earth rods, surge arresters, R < 5 Ohm	1	lot

Quantities are indicative for preliminary budgeting. Cable runs and civil works require a detailed site survey. Excludes grid connection, planning permits, insurance, EPC margin, and land acquisition.


Contact info@sade.systems for a detailed quotation

8. Battery Storage (BESS) Investment Analysis [BESS]

System Summary

Storage Capacity	59,475 kWh (59.48 MWh)
PCS Power	29,738 kW (C-rate 0.5)
Container Size	5,000 kWh per container
Number of Containers	12
Annual Cycles	365 cycles/yr
Annual Charged	19,537,538 kWh/yr (19537.5 MWh/yr)
Annual Discharged	17,583,784 kWh/yr (17583.8 MWh/yr)
Round-Trip Losses	1,953,754 kWh/yr
Tariff Spread	8.00 c-EUR/kWh (peak - off-peak)

Indicative Site Layout



Schematic site arrangement (indicative, not to scale). 12 × 5000 kWh containers, 6 × 5000 kVA MV step-up TX, 40.0 MVA main HV TX.

Financial Summary


Total CAPEX	EUR 18,883,312 (318 EUR/kWh all-in)
OPEX / Year	EUR 283,250/yr

Year-1 Net Cashflow	EUR 3,294,291
Year-1 Revenue (total)	EUR 3,577,540
IRR	15.9% (20-year DCF)
NPV	EUR 14,045,433
Simple Payback	5.8 years
LCOE	14.32 c-EUR/kWh (discounted energy cost)


Year-1 Revenue Breakdown

Arbitrage (price spread)	EUR 1,406,703 (39%)
FCR (Frequency Containment Reserve)	EUR 892,125 (25%)
aFRR (auto Frequency Restoration Reserve)	EUR 446,062 (12%)
mFRR (manual Frequency Restoration Reserve)	EUR 237,900 (7%)
Capacity Market	EUR 594,750 (17%)

20-Year Cumulative Cashflow



Monthly Discharge Profile (Year 1)



Bill of Quantities (BOQ)

Component	Qty	Unit	Note
LFP battery container (5 MWh / 20-ft)	12	pcs	59.5 MWh total, incl. BMS
Spare battery modules (2%)	1	pcs	O&M; stock

Bidirectional PCS (~2480 kW)	12	pcs	29.7 MW total, 4Q inverter
5000 kVA LV/MV step-up transformer	6	pcs	0.4/10(20) kV, ~2 container(s)/unit
MV switchgear / ring main unit	1	set	IEC 62271-202
LV AC cable 240 mm2 (3-phase)	1440	m	container to transformer
MV cable 95 mm2 (3-phase)	2700	m	to grid point of connection
HVAC / thermal management	12	set	container climate control
Fire detection & suppression	12	set	NFPA 855 / FM Approved
Container foundation / plinth	12	pcs	concrete pad
Earthing & lightning protection	1	set	IEC 62305
EMS / SCADA + market interface	1	lot	IEC 62933-5-1
Revenue-grade metering	6	pcs	MID-certified
Civil works (fencing + access)	504	m2	42 m2/container incl. clearances

Rule-of-thumb quantities for preliminary design and budgeting. Excludes grid connection, permits, EPC margin and land. Detailed engineering required per NFPA 855 / IEC 62933.

9. PV + Storage Dispatch & Combined Economics [PV+BESS]

In a co-located PV + storage plant the battery is charged primarily by on-site solar generation; surplus PV is exported directly to the grid, and the stored energy is shifted to higher-value peak and ancillary-service windows. The flows below quantify this operating strategy.

Annual Energy Flows

PV generation (AC)	26,534,404 kWh/yr (26534.4 MWh)
PV -> battery (charging)	19,537,538 kWh/yr (19537.5 MWh)
PV -> grid (direct export)	6,996,866 kWh/yr (6996.9 MWh)
Grid -> battery (top-up)	0 kWh/yr
Battery discharge	17,583,784 kWh/yr (17583.8 MWh)
Battery charging covered by PV	100%
PV cycled through battery	73.6% (rest exported directly)
PV exported directly	26.4%




Figure — Annual energy dispatch flows (MWh). PV generation is split between direct battery charging and direct grid export. Battery column shows charge sources (from PV vs. grid top-up). Discharge column shows energy delivered to the grid.

PV Self-Supply Benefit (indicative)

On-site PV charging cost	3.94 c-EUR/kWh (PV LCOE)
Avoided grid off-peak cost	7.00 c-EUR/kWh
Energy charged from PV	19,537,538 kWh/yr
Annual self-supply benefit	EUR 597,849/yr

Indicative upside from charging the battery with on-site PV (at its LCOE) instead of purchasing grid power at the off-peak tariff. Shown separately; the combined NPV/IRR below treats the PV and BESS revenue streams independently (conservative).

Combined Project Economics

Total CAPEX (PV + BESS)	EUR 27,804,715 (27.80 M-EUR)
Combined IRR	28.8%
Combined NPV	EUR 65,923,552 (65.92 M-EUR)
Combined Payback	3.5 years




Figure — Cumulative cashflow over project lifetime. Green = PV standalone, Cyan = BESS standalone, Violet = combined portfolio. The combined curve reaches breakeven at the marked payback year.

Combined figures aggregate the PV plant and the battery system. PV export revenue and BESS arbitrage / ancillary revenue are modelled independently; the dispatch flows above describe the physical integration of the two assets.

10. Methodology & Standards Reference

Solar PV

Component	Method / Model	Reference
Solar geometry	Sun position -- zenith, azimuth, hour angle	ISO 52010-1:2017
Irradiance transposition	GHI -> POA sky diffuse + ground-reflected	IEC 61853-3:2018 Annex B
Cell temperature	Thermal derating above 25 degC STC (U0 + U1 x wind speed)	IEC 61215-2:2021 S8
IAM correction	Fresnel + Beer-Lambert physical model	IEC 61853-2:2016
Energy loss cascade	10-step sequential loss chain	IEC 61724-1:2021 S6.2
Bifacial rear irradiance	Infinite-sheds, rear-side albedo-weighted	IEEE 1907.1-2020
DC string sizing	Voltage at temperature extremes	IEC 62548:2016 S4.6
Uncertainty analysis	Monte Carlo 2 000 samples, lognormal RSS	IEC 61724-1:2021 Annex C
Financial DCF	25-yr NPV / IRR / LCOE / CO2	IEC TR 62936:2020
Weather data source	TMY per Finkelstein-Schafer statistics	ISO 15927-4:2005; PVGIS 5.2 (JRC)
Weather cross-validation	Independent PVGIS 5.2 vs NASA POWER GHI check	IEC 61724-1:2021 S5.2

Battery Storage

Component	Method / Model	Reference
BESS sizing	Capacity -> container count; PCS at C-rate 0.5	IEC 62933-2-1:2018
Round-trip efficiency	AC-AC efficiency incl. PCS + auxiliary draw	IEC 62933-2-1:2018 S6
Capacity degradation	Calendar + cycle ageing, linear fade per year	IEC 62933-5-2:2020
Energy arbitrage	Off-peak charge / peak discharge dispatch	Tariff spread model
Ancillary services	FCR / aFRR / mFRR capacity revenue stacking	EU 2017/1485 (SO GL)
Capacity market	De-rated capacity availability payment	EU 2019/943 Art. 21-27
Financial DCF	20-yr NPV / IRR / LCOS / payback	IEC 62933-1; IRENA ESVT
Safety & fire	Container fire detection + suppression	NFPA 855:2023; IEC 62933-5-2
Grid connection	MV step-up + protection coordination	IEEE 1547-2018; IEC 62271-202

PVGIS 5.2 data: (c) European Union 2001-2024 (Joint Research Centre, European Commission). NASA POWER data: NASA Langley Research Center (LaRC) POWER Project. Standards: IEC (International Electrotechnical Commission), ISO (International Organization for Standardization), IEEE (Institute of Electrical and Electronics Engineers). Battery standards: IEC 62933 (electrical energy storage systems), NFPA 855:2023 (stationary energy storage installations), EU 2017/1485 & EU 2019/943 (European electricity market & balancing). Revenue assumptions reflect 2024-25 European ancillary-service averages and should be confirmed against the local TSO/DSO market rules.

11. Disclaimer

This pre-feasibility report has been prepared by SADE PVInvest solely for informational purposes. energy yield and financial projections are based on computer simulation using PVGIS 5.2 TMY data for the PV plant and battery dispatch / market-revenue assumptions for the storage. Actual performance may differ materially due to: inter-annual meteorological variability, market price volatility, ancillary-service rule changes, equipment degradation, soiling, grid curtailment, actual costs, and regulatory changes.

This report is not an independent technical energy assessment. Users should commission an independent technical due diligence study before project development or financing.

PVGIS data: (c) European Union 2001-2024 (JRC). Generated by SADE PVInvest on 12 June 2026.